CERTIFICATE

Number	20GR0352/00	**Replaces**	--
Issue date	24-07-2020	**Contract number**	E8090
Due date	24-07-2030	**Module**	B (Type testing)
Report number	190701987	**Scope**	(EU) 2016/426 (9 March 2016)
PIN	0063DL3987		

EU TYPE EXAMINATION CERTIFICATE (GAR)

Kiwa hereby declares that the condensing central heating boilers, type(s):

DemirDöküm isomiX P 35-CS/1 (N-TR)

Manufacturer **TÜRK DEMIRDÖKÜM FABRIKALARI A.S.**
Bozüyük, Turkey

meet(s) the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard: EN 15502-1:2012+A1:2015 and EN 15502-2-1-2012+A1:2016

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Kiwa Nederland B.V.
Wilmersdorf 50
P.O. Box 137
7300 AC APELDOORN
The Netherlands
www.kiwaenergy.com
GASTEC

Ron Scheepers
Kiwa

Number	20GR0352/00	**Replaces**	--
Issue date	24-07-2020	**Contract number**	E8090
Due date	24-07-2030	**Module**	B (Type testing)
Report number	190701987	**Scope**	(EU) 2016/426 (9 March 2016)
PIN	0063DL3987	**Page**	1 of 1

APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

Manufacturer:
TÜRK DEMIRDÖKÜM FABRIKALARI A.S.

Types:

	Heat input	
Model name	CH (kW - Hi)	DHW (kW - Hi)
DemirDöküm isomiX P 35-CS/1 (N-TR)	3.6 – 30.6	3.6 – 34.8

Model name	Appliance categories		Countries
DemirDöküm isomiX P 35-CS/1 (N-TR)	II_{2H3P}	G20 – 20 mbar G31 – 37 mbar	Turkey

Model name	Appliance types	Flue installation manuals (use latest version)	Article number back flow valve with manual
DemirDöküm isomiX P 35-CS/1 (N-TR)	B_{23}, B_{23P}, B_{33}, C_{13}, C_{33}, C_{43}, C_{53}, C_{83}, C_{93}	0020294220	-

Remarks:
--